



Compagnia Tecnica Motori S.p.A.

I-20090 Cesano Boscone (MI)
Via Magellano, 1
Tel. +39 02.450581 (20 linee r.a.)
Fax +39 02.45058260 / 262

Magazzino Ricambi:
Fax diretto +39 02.45058263
www.ctm.it
e-mail: ctm@ctm.it



	PROJECT NAME: Salah Methanol Project
Salah Methanol Project	OWNER: Salah Methanol Company, LLC (FZC)
	SITE : Salah, Sultanate of Oman

AUTOMATIC MAINS FAILURE GENERATING SETS TRAINING MANUAL

ITEM 20-GPC-502A FOR 20-Z2902A GENSET 1 (2875 KVA – 11KV – 50Hz)

ITEM 20-GPC-502B FOR 20-Z2902B GENSET 2 (2875 KVA – 11KV – 50Hz)

ITEM 20-GPC-502C FOR 20-Z2902C GENSET 3 (2875 KVA – 11KV – 50Hz)

Vendor: Compagnia Tecnica Motori S.p.A.	Purchase Order: 7S72-PO-EL-001
Vendor's Job: 6608	

A	11.03.09	Issued for approval with elec. DWG as built	F.T (TE)	E.T. (TE)	
REV.	DATE	Description	PRPD	CHKD	APPR



EDG TRAINING MANUAL JOB 6608 REV.0

Index

1. Introduction

- 1.1. Supply Technical Description
- 1.2. General Diesel Generator Introduction Manual

2. Engine

- 2.1. MTU Manual
- 2.2. P&ID
 - 2.2.1. Lube Oil System
 - 2.2.2. Fuel System
 - 2.2.3. Cooling System

3. Coupling

4. Alternator

- 4.1. Installation
- 4.2. Maintenance
- 4.3. Alternator Wiring Diagram
- 4.4. AVK MA330 Automatic Voltage Regulator

5. Installation

- 5.1. Installation DWG
- 5.2. Civil Works DWG
- 5.3. General Arrangement DWG EDG set
- 5.4. Piping Isometric DWG
- 5.5. Piping Gas Extinguishing Sys DWG

6. GE Control Panel

- 6.1. Generator Set Electric diagram 6608-E-400-6 (2008.017A Rev.6)
- 6.2. Control System Configuration and Philosophy
- 6.3. Main Components on Control Panel
 - 6.3.1. DST4601 board
 - 6.3.2. DST4601 parameters



Compagnia Tecnica Motori S.p.A.

I-20090 Cesano Boscone (Mi)
Via Magellano, 1
Tel. +39 02.450581 (20 linee r.a.)
Fax +39 02.45058260 / 262

Magazzino Ricambi:
Fax diretto +39 02.45058263
www.ctm.it
e-mail: ctm@ctm.it



- 6.3.3. MD32-G Differential Electric Protection
- 6.3.4. RB4 Cat. J4-93 Lock-out Relay
- 6.3.5. MG30 Multifunction Protection Relay
- 6.3.6. MG30 Configuration
- 6.3.7. IM30-B00 Microprocessor Earth Fault Protection Relay
- 6.3.8. Electronic Potentiometer
- 6.3.9. GE Fanuc PLC
- 6.3.10. PLC List
- 6.3.11. Winding and Bearing Temperature Detection Relay
- 6.3.12. Automatic Battery Charger

7. Synchronizing Control Panel

- 7.1. Synchronizing Electric diagram 6608-E-401-7 (2008.019 Rev.7)
- 7.2. Main Components on Panel
 - 7.2.1. DEIF GPU Load Sharing
 - 7.2.2. Manual Parallel Check Verifier

8. Accessories

- 8.1. Fire Fighting System
- 8.2. P&ID Fire Fighting System
- 8.3. Flame Arrestor
- 8.4. Air Station
- 8.5. Engine Air Starter
- 8.6. Air System Certificate
- 8.7. General Arrangement Load Bank
- 8.8. Neutral Grounding Resistor
- 8.9. Fuel Tank 700 litres
- 8.10. Fuel Tank 45000 litres
- 8.11. Fuel Tank Certificate